



2025

Drinking Water System

Annual Water Quality & Performance Report

Table of Contents

Abstract	3
1.0 Introduction	4
1.1 Background Information and Reporting Requirements	4
1.2 Annual Report Requirements.....	4
2.0 Supporting Evidence for Section 11 Report Requirements	5
2.1 Location and Availability of Annual Report(s)	5
2.2 Drinking Water System Description.....	5
2.3 Major Monetary Expenses.....	6
3.0 Drinking Water Quality Performance	6
3.1 Water Quality Data.....	6
3.1.1 Operational Testing Completed Under Schedule 7.....	6
3.1.2 Microbiological Testing Completed Under Schedule 10.....	6
3.1.3 Summary of Testing Pursuant to Schedule 13	7
3.1.4 Lead Testing Completed Under Schedule 15.1.....	7
3.1.5 Organic and Inorganic Parameters Under Schedules 23 & 24	7
4.0 MECP Inspection(s), Regulatory Reporting & Corrective Actions	8
4.1 Annual Ministry Inspection Results.....	8
4.2 Adverse Water Quality Incidents (AWQI)	8
4.2.1 Notices Submitted Under Schedule 16 (Duty to Report).....	8
5.0 Additional Sampling and Testing Results	9
5.1 Summary of Organic Parameters Tested Pursuant to Schedule 23	9
5.2 Summary of Inorganic Parameters Tested Pursuant to Schedule 24	10
Appendix A: 2025 Drinking Water Quality Summary Analysis	11
Appendix B: MECP Inspection Rating Record (IRR)	14



Abstract

This report contains information necessary to satisfy the annual reporting requirements within the Ontario Safe Drinking Water Act, 2002, and associated regulations.

Prepared by the Town of Newmarket pursuant to Section 11 of O. Reg. 170/03.

Drinking Water System Number:	260003188
Drinking Water System Name:	Newmarket Distribution System
Drinking Water System Owner:	The Town of Newmarket
Drinking Water System Category:	Large Municipal Residential
Reporting Period:	01-Jan-2025 to 31-Dec-2025



1.0 Introduction

Newmarket Water (operating authority) acting on behalf of the Corporation of the Town of Newmarket (owner) has prepared this Annual Water Quality and Performance Report to satisfy the legal requirements set out in Section 11 of O. Reg. 170/03. This report functions primarily to inform the drinking water system owner(s) of Newmarket Water's adherence to its compliance requirements, as well as adequate conformance with industry Best Management Practices.

The intended purpose of this report is to provide Newmarket Council and the public with the information necessary to evaluate the quality and effectiveness of the drinking water being provided within the Town of Newmarket and ensuring its delivery in a safe and proficient manner.

1.1 Background Information & Reporting Requirements

This Annual Water Quality & Performance Report is prepared in accordance with subsections (3) and (6) of O. Reg. 170/03, s.11. The information contained in this report outlines the drinking water system's performance for the preceding year, which details up to and including:

- Reported adverse water quality incidents (AWQIs) & corrective actions (*Section 4.2.1*)
- Monetary expenses for the drinking water system (*Section 2.3*)
- Water quality data (*Section 3.1.1 to 3.1.5*)
- Drinking water quality summary analysis (*Appendix A*)
- Ministry (MECP) inspection results & findings (*Appendix B*)

1.2 Annual Report Requirements

Section 11 requires The Corporation of the Town of Newmarket (owner) to include the following information in this report for the prescribed reporting period:

- i. A brief description of the Drinking Water System (DWS), including a list of water treatment chemicals used by the system (if applicable).
- ii. A summary of adverse test results and other observations that were reported to the MECP during the reporting period. (Schedule 16)
- iii. A description of any corrective actions that were taken in response to any adverse test results and other observations that were encountered during the reporting period (Schedules 17 and 18)
- iv. A summary of the most recent water testing results, required under O. Reg. 170/03 and the Town of Newmarket's Municipal Drinking Water Licence (MDWL), that occurred during the reporting period.
- v. A description of the major expenses incurred during the reporting period to install, repair, or replace required equipment/infrastructure.
- vi. A statement identifying the locations where the annual report will be made available for the public; and
- vii. The specific number of points sampled during the lead sampling periods identified within O. Reg. 170/03 as well as the total number of samples taken, and the number of points where a sample exceeded the prescribed standard for lead (Schedule 15.1)



2.0 Supporting Evidence for Section 11 Report Requirements

2.1 Location & Availability of Annual Report(s)

It is a requirement that the owner(s) of the drinking water system take the necessary steps to advise users of the annual reports availability, and the means to which they can be obtained. The annual and summary reports for the Town of Newmarket's municipal water system are posted at www.newmarket.ca. Copies of each report prepared in accordance with Section 11 and Schedule 22 of O. Reg. 170/03 are available at no cost to the public and for inspection at:

- Robert N. Shelton Operations Centre (1275 Maple Hill Court)
- Newmarket Municipal Offices, Customer Service Counter (395 Mulock Drive)

Online at www.newmarket.ca/waterqualityreports

2.2 Drinking Water System Description

Detailed information regarding the Town of Newmarket's drinking water system is outlined in the following section. The primary aim is to inform council as well as the public regarding Newmarket Water's approach in providing safe, high-quality drinking water.

The Newmarket Distribution System (DS) is classified as a Large Municipal Residential Class 1 subsystem which purchases water from the Regional Municipality of York. The Region operates and maintains groundwater wells sourced from the Yonge Street aquifer which services the Town of Newmarket and its users. The water distribution system components and linear assets owned and operated by Newmarket Water consists of:

- 27,095 water services
- 2,761 mainline valves
- 2,270 fire hydrants
- 30 sample stations
- 318 km of municipal watermain
- 9 permanent auto flushers (2 intelligent)
- 6 anti-stagnation valves
- 6 combination valves (air relief/vacuum relief)
- 5 air release valves
- 4 pressure zones (west, central west, east, central east)

Water in the distribution system is profiled as blended due to the potential mixing of groundwater from the Newmarket and Aurora wells with surface water sourced from Lake Ontario. York Region operates the water supply to the system, while Newmarket Water (operating authority) maintains and distributes the water to the user. The integrated system includes Newmarket's localized watermains and service connections, in partnership with, the Regional Municipality of York's transmission mains, pumping stations, storage facilities and groundwater treatment facilities. Additionally, the Town of East Gwillimbury receives their drinking water from the Newmarket Drinking Water System (DWS). Receiving systems for the Newmarket Distribution System (DS) are as follows:

- DWS No. 260001747 – Holland Landing/Queensville/Sharon Distribution System
- DWS No. 260087685 – Yonge-Green Lane Distribution System

Water from York Region's supply network is continuously monitored by staff at their centralized remote-operations center through a SCADA (Supervisory Control and Data Acquisition) system. Newmarket Water and Central York Water work collaboratively to deliver safe and clean water to their users from source to tap. The Region produces and provides their own independent Annual Drinking Water Quality Report as well as a Drinking Water Systems Report which provides further detailed information on Newmarket Drinking Water System (DWS). These reports are also made publicly available and can be found on their website at:

www.york.ca/environment/water-and-wastewater/drinking-water-quality-and-monitoring

Newmarket Water does not produce or provide chemical water treatment. Chemical addition is completed by York Region. Chlorine is added to achieve primary disinfection, chloramines to provide secondary disinfection, and sodium silicate to sequester naturally occurring iron and manganese in the groundwater supplies.



2.3 Major Monetary Expenses (Installations, Repairs, Replacements)

\$2,817,272 for planned/unplanned maintenance, capital projects and commissioning, valve chamber repairs, equipment repair and maintenance, general maintenance activities up to and including the installation, replacement and repair of hydrants, valves, services and watermains in the distribution system.

3.0 Drinking Water Quality Performance (Sampling & Testing Results)

3.1 Water Quality Data

The sampling program for the Newmarket Distribution System consists of regulated sampling and testing, in-house sampling, and enhanced monitoring program(s). Operations staff complete these various sampling programs based on operational necessity, and as required by the legislative framework under the Safe Drinking Water Act and its regulations.

Under O. Reg. 170/03 and the Ontario Drinking Water Quality Standards (ODWQS), the regulated testing classifications that are mandatory for the sampling of the Newmarket Distribution System (DS) consist of:

- Schedule 7 – Operational Checks (Combined Chlorine Residuals)
- Schedule 10 – Microbiological Sampling and Testing
- Schedule 13 – Chemical Sampling and Testing
 - Organic Parameters
 - Trihalomethanes (THM) and Haloacetic Acids (HAA),
 - Nitrosodimethylamine (NDMA)
 - Inorganic Parameters
 - Nitrate (NO₂ as N) and Nitrite (NO₃ as N)
 - Sodium (Na) and Fluoride (F)
- Schedule 15.1 – Lead Testing
- Schedules 23, 24 - Additional Organic and Inorganic Parameters

Some of these parameters require sampling and testing at the point where water enters the distribution system (completed by York Region). The regulated results for these sample types can be found in the water quality data and [annual reports](#) provided by York Region.

Please refer to **Appendix A – “Drinking Water Quality Summary Analysis”** for additional data related to regulated sampling and testing results for the Newmarket Distribution System in 2025.

3.1.1 Operational testing completed under Schedule 7 of O. Reg. 170/03 during this reporting period

Parameter	Number of Grab Samples During Reporting Period	Range of Results (min.) (max.)	Unit of Measure
Combined Chlorine	3,517	0.06 – 3.50	mg/L or ppm

3.1.2 Microbiological testing completed under Schedule 10 of O. Reg. 170/03

Parameter	Samples During Reporting Period	Range of Results (min.) (max.)	No. Count of Presence	Unit of Measure
E. Coli	1,381	Absence – Absence	0	P-A/100 mL
Total Coliforms	1,381	Absence – Presence	4	P-A/100 mL
Heterotrophic Plate Count	338	0 - 300	0	CFU/mL



3.1.3 Summary of testing pursuant to Schedule 13 of O. Reg. 170/03 and sampling carried out in accordance with the requirement of an approval, order, or another legal instrument.

Organic/Inorganic Parameter	Sample Dates for Reporting Period		Range of Results (min.) (max.)	Unit of Measure	Regulatory Limit	Overlimit Value
Organics						
Trihalomethanes (THM)	13-Jan 14-Apr	14-July 06-Oct	9.2 – 29.7	µg/L	100	0
Haloacetic Acids (HAA)	13-Jan 14-Apr	14-July 06-Oct	<8.0 – 9.7	µg/L	80	0
Nitrosodimethylamine (NDMA)	10-Mar 16-Jun	15-Sep 15-Dec	<0.0009	µg/L	0.09	0
Inorganics						
Nitrate (NO ₃) as N	20		<0.50 – 0.70	mg/L	10	0
Nitrite (NO ₂) as N	262		<0.05 – 0.14	mg/L	1.0	0
Sodium (Na)	20		14.4 – 20.8	mg/L	20	0
Fluoride (F)	198		0.16 – 0.952	mg/L	1.5	0

3.1.4 Lead testing completed under Schedule 15.1 of O. Reg. 170/03

Location Type	No. of Samples for Reporting Period	Range of Lead Results (min.) (max.)	Unit of Measure	Overlimit Value
Plumbing Network	n/a	n/a	n/a	n/a
Distribution System	16	<0.0005	mg/L	0

Regulatory relief for lead under Schedule D of the Newmarket Distribution System's MDWL (Municipal Drinking Water Licence; 124-101) requires eight (8) sample points to be tested during each of the two sampling periods prescribed under O. Reg. 170/03. All tests for lead (Pb) in the drinking water system are performed by licenced staff and are significantly below the threshold limit of 0.01 mg/L which is detailed below.

Newmarket Water (operating authority) is regulated to test for the presence of lead within the distribution system it operates and maintains but is not required to test within the adjoining private service connections. In Ontario, the drinking water quality standard for lead (Pb) is 10 micrograms per litre (10 µg/L) or 0.010 milligrams per litre (0.010 mg/L). This standard is based on the national guideline set out by Health Canada. The Ministry has amended regulations under the Safe Drinking Water Act to introduce lead testing exemptions within private plumbing networks for municipal drinking water systems.

3.1.5 Organic and inorganic parameter(s), from Schedule 23 and 24, that exceed half the standard prescribed in Schedule 2 of O. Reg. 169/03 (ODWQS)

Location Type	No. of Samples for Reporting Period	Range of Results (min.) (max.)	Unit of Measure	No. of Exceedances
---------------	-------------------------------------	--------------------------------	-----------------	--------------------

Not Applicable.

Intentionally blank. There were no applicable test results for the reporting period.



4.0 Ministry of the Environment, Conservation and Parks (MECP) Inspection(s), Regulatory Reporting & Corrective Actions

4.1 Annual Ministry Inspection Results

An unannounced MECP on-site inspection was conducted on October 25th, 2025, with a primary focus on verifying the Town of Newmarket’s adherence to the regulatory requirements outlined in O. Reg. 170/03 and validating the provisional compliance conditions described under the Safe Drinking Water Act. Compliance with O. Reg. 170/03 is determined through a systematic inspection of the operating authority’s processes, procedures, and operations manuals, as well as a thorough review of all records and documentation to support and affirm that the provinces’ regulatory requirements were met.

Through an assessment, each local and regional municipality (lower and upper tier) are issued an IRR (inspection rating record) by the Ministry on their system and water quality testing results. The IRR grading system produces a non-compliance risk score associated with various criteria defined under six (6) predetermined inspection modules. For a fifth year in a row the Newmarket DS and Newmarket Water Department received a perfect score of 100% from the MECP inspector. There were no issued notices or reported incidents of non-compliance associated with the Town of Newmarket’s water system.

See **Appendix B for the official “Inspection Rating Record (IRR)”** issued by the Ministry (MECP) on November 12th, 2025.

4.2 Adverse Water Quality Incidents (AWQI)

4.2.1 Notices submitted under Section 18(1) of the Safe Drinking Water Act or Section 16-4 of Schedule 16 of O. Reg. 170/03 and reported to MECP SAC

Incident Description	Incident Date (yyyy mm dd)	Adverse Test Result	(CA) Corrective Actions	CA Date (yyyy mm dd)
Combined Chlorine Residual < 0.25 mg/L	2025-04-28	0.22 mg/L	Flushed affected area(s).	2025-04-28
	2025-06-09	0.14 mg/L	Resampled/tested	2025-06-09
	2025-06-18	0.24 mg/L	(upstream, downstream, at the source).	2025-06-18
	2025-06-24	0.22 mg/L		2025-06-25
	2025-06-30	0.24 mg/L	Results acceptable by field testing and measurement	2025-06-30
	2025-11-04	0.19 mg/L	equipment.	2025-11-04
	2025-11-17	0.19 mg/L		2025-11-17
Positive Lab Test for Suspected Presence of Total Coliforms (TC)	2025-11-24	0.14 mg/L	Normal operation restored.	2025-11-24
	2025-07-01	(P)A/100mL	Flushed affected area(s).	2025-07-08
	2025-07-09	(P)A/100mL	Resampled/tested.	2025-07-14
	2025-07-15	(P)A/100mL	Results acceptable by accredited lab.	2025-07-19
	2025-07-15	(P)A/100mL		2025-07-19



5.0 Additional Sampling & Testing Results

5.1 Summary of organic parameters tested pursuant to O. Reg. 170/03; Schedule 23

Organic Parameter	Sample Date for Reporting Period	Result Value	Unit of Measure	No. of Exceedances
Alachlor				
Aldicarb				
Aldrin + Dieldrin				
Atrazine + N-dealkylated metabolites				
Azinphos-methyl				
Benzene				
Benzo(a)pyrene				
Bromoxynil				
Carbaryl				
Carbofuran				
Carbon Tetrachloride				
Chlorpyrifos				
Diazinon				
Dicamba				
1,2 – Dichlorobenzene				
1,4 – Dichlorobenzene				
1,2 – Dichloroethane				
1,1 – Dichloroethylene				
Dichloromethane				
2,4 – Dichlorophenol				
2,4 – Dichlorophenoxy acetic acid				
Diclofop-methyl				
Dimethoate				
Diquat				
Diuron				
Glyphosate				
Malathion				
2-Methyl-4-chlorophenoxyacetic acid				
Metolachlor				
Metribuzin				
Monochlorobenzene				
Paraquat				
Pentachlorophenol				
Phorate				
Picloram				
Polychlorinated Biphenyls (PCB)				
Prometryne				
Simazine				
Terbufos				
Tetrachloroethylene				
2,3,4,6 – Tetrachlorophenol				
Triallate				
Trichloroethylene				
2,4,6 – Trichlorophenol				
Trifluralin				
Vinyl Chloride				

Under O. Reg. 170/03 these parameters are required to be tested at a point where water enters the distribution system from the supply/source.

The Town of Newmarket relies on York Region to complete the sampling schedule for these inorganic parameters as water leaves the supply system(s) & treatment facilities.

Please refer to annual report(s) provided by the Regional Municipality of York for additional data.



5.2 Summary of inorganic parameters tested pursuant to O. Reg. 170/03; Schedule 24

Inorganic Parameter	Sample Date for Reporting Period	Result Value	Unit of Measure	No. of Exceedances
Antimony				
Arsenic				
Barium				
Boron				
Cadmium				
Chromium				
Mercury				
Selenium				
Uranium				

Under O. Reg. 170/03 these parameters are required to be tested at a point where water enters the distribution system from the supply/source.

The Town of Newmarket relies on York Region to complete the sampling schedule for these inorganic parameters as water leaves the supply system(s) & treatment facilities.

Please refer to annual report(s) provided by the Regional Municipality of York for additional data.

Drinking Water Quality Summary Analysis

2025



Microbiological Sampling Sched. 10										
E. Coli (Presence/Absence)										No
Total Coliforms (Presence/Absence)	CFU/100 mL	Jan. 1 to Dec. 31	1381	0 to > 80	Presence	Absence	99.7 %	n/a	0 / ND	Yes
Heterotrophic Plate Count	CFU/mL	Jan. 1 to Dec. 31	338	>3.0 x 10 ³	300	0	2.17	n/a	n/a	No
Operational Checks Sched. 7										
Combined Chlorine (Chloramines)	mg/L	Jan. 1 to Dec. 31	3516	0.25	3.50	0.06	1.65	n/a	4.0	Yes
Turbidity	NTU	Jan. 1 to Dec. 31	365	n/a	1.98	0.32	0.62	5.0	0	
Trihalomethanes (THM)	µg/L	Jan to Oct	48	100	29.7	9.2	14.6	n/a	100	No
Haloacetic Acids (HAA)	µg/L	Jan to Oct	16	80	9.7	<8.0	1.77	n/a	80	No
Nitrosodimethylamine (NDMA)	µg/L	Mar to Dec	4	0.09	<0.001	<0.001	<0.001	n/a	0.04	No
Nitrate (NO ₂ as N)	mg/L	Jan 1 to Dec. 31	20	10	0.7	<0.50	0.07	n/a	10	n/a
Nitrite (NO ₃ as N)	mg/L	Jan. 1 to Dec. 31	414	1	0.45	0.00	0.02	n/a	1	No
Sodium (Na)	mg/L	May & Nov	20	20	20.8	14.4	17.3	200	20	n/a
Fluoride (F)	mg/L	Jan. 1 to Dec. 31	274	1.5	0.64	0.16	0.39	n/a	1.5	No
Plumbing Network	mg/L	n/a	0	0.00005	n/a	n/a	n/a	n/a	0.010	n/a
Distribution System	mg/L	Jan. 1 to Dec. 31	16	0.00005	<0.0005	<0.0005	<0.0005	n/a	0.010	No



Sampling Requirements Pursuant to O. Reg. 170/03	Unit	Sampling Period	No. of Samples	Reporting Limit	Maximum	Minimum	Average	Aesthetic Objective	MAC	Overlimit Value
Inorganic Parameters Sched. 23										
	mg/L	Not Required	0	0.00005	-	-	-	-	0.01	n/a
	mg/L	Not Required	0	0.00001	-	-	-	-	0.005	n/a
	mg/L	Not Required	0	0.00005	-	-	-	-	0.001	n/a
	mg/L	Not Required	0	0.00005	-	-	-	-	0.02	n/a
Organic Parameters Sched. 24										
Alachlor	µg/L	Not Required	0	0.0005	-	-	-	-	5	n/a
Aldicarb	µg/L	Not Required	0	-	-	-	-	-	-	n/a
Aldrin + Dieldrin	µg/L	Not Required	0	-	-	-	-	-	-	n/a
Atrazine + N-dealkylated metabolites	µg/L	Not Required	0	0.0025	-	-	-	-	5	n/a
Azinphos-methyl	µg/L	Not Required	0	0.001	-	-	-	-	20	n/a
Benzene	µg/L	Not Required	0	0.1	-	-	-	-	1	n/a
Benzo(a)pyrene	µg/L	Not Required	0	0.01	-	-	-	-	0.01	n/a
Bromoxynil	µg/L	Not Required	0	0.075	-	-	-	-	5	n/a
Carbaryl	µg/L	Not Required	0	0.0015	-	-	-	-	90	n/a
Carbofuran	µg/L	Not Required	0	0.0025	-	-	-	-	90	n/a
Carbon Tetrachloride	µg/L	Not Required	0	0.2	-	-	-	-	2	n/a
Chlorpyrifos	µg/L	Not Required	0	0.01	-	-	-	-	90	n/a
Diazinon	µg/L	Not Required	0	0.0005	-	-	-	-	20	n/a
Dicamba	µg/L	Not Required	0	0.2	-	-	-	-	120	n/a
1,2 - Dichlorobenzene	µg/L	Not Required	0	0.2	-	-	-	3	200	n/a
1,4 - Dichlorobenzene	µg/L	Not Required	0	0.2	-	-	-	-	5	n/a
1,2 - Dichloroethane	µg/L	Not Required	0	0.2	-	-	-	-	5	n/a
1,1 - Dichloroethylene	µg/L	Not Required	0	0.2	-	-	-	-	14	n/a
2,3,4,6 - Tetra chlorophenol	µg/L	Not Required	0	1.0	-	-	-	1	100	n/a
1,4 - Dichlorobenzene	µg/L	Not Required	0	0.2	-	-	-	1	5	n/a
1,2 - Dichloroethane	µg/L	Not Required	0	0.2	-	-	-	-	5	n/a
2,4,6 - Trichlorophenol	µg/L	Not Required	0	0.5	-	-	-	-	5	n/a
Dichloromethane	µg/L	Not Required	0	0.3	-	-	-	-	50	n/a
2,4 - Dichlorophenol	µg/L	Not Required	0	0.5	-	-	-	-	900	n/a
2,4 - Dichlorophenoxy acetic acid	µg/L	Not Required	0	-	-	-	-	-	100	n/a
Diclofop-methyl	µg/L	Not Required	0	0.5	-	-	-	-	9	n/a
Dimethoate	µg/L	Not Required	0	0.001	-	-	-	-	20	n/a
Diquat	µg/L	Not Required	0	1.0	-	-	-	-	70	n/a
Diuron	µg/L	Not Required	0	0.001	-	-	-	-	150	n/a
Glyphosate	µg/L	Not Required	0	25	-	-	-	-	280	n/a
Malathion	µg/L	Not Required	0	0.001	-	-	-	-	190	n/a
2-Methyl-4-chlorophenoxyacetic acid	µg/L	Not Required	0	0.2	-	-	-	-	100	n/a



Sampling Requirements Pursuant to O. Reg. 170/03	Unit	Sampling Period	No. of Samples	Reporting Limit	Maximum	Minimum	Average	Aesthetic Objective	MAC	Overlimit Value
Organic Parameters (Continued)										
Monochlorobenzene	µg/L	Not Required	0	0.2	-	-	-	-	80	n/a
Paraquat	µg/L	Not Required	0	1.0	-	-	-	-	10	n/a
Pentachlorophenol	µg/L	Not Required	0	0.5	-	-	-	30	60	n/a
Phorate	µg/L	Not Required	0	0.01	-	-	-	-	2	n/a
Picloram	µg/L	Not Required	0	0.3	-	-	-	-	190	n/a
Polychlorinated Biphenyls (PCB)	µg/L	Not Required	0	0.3	-	-	-	-	3	n/a
Prometryne	µg/L	Not Required	0	0.0005	-	-	-	-	1	n/a
Simazine	µg/L	Not Required	0	0.001	-	-	-	-	10	n/a
Terbufos	µg/L	Not Required	0	0.006	-	-	-	-	1	n/a
Tetrachloroethylene	µg/L	Not Required	0	0.2	-	-	-	-	10	n/a
Trifluralin	µg/L	Not Required	0	0.265	-	-	-	-	45	n/a
Triallate	µg/L	Not Required	0	0.01	-	-	-	-	230	n/a
Trichloroethylene	µg/L	Not Required	0	0.2	-	-	-	-	5	n/a
Vinyl Chloride	µg/L	Not Required	0	0.1	-	-	-	-	1	n/a

All inorganic (Schedules 23 & 13) and organic (Schedule 24) parameters listed as “Not Required” are completed by The Regional Municipality of York as per O. Reg. 170/03 and can be found in York Region’s Drinking Water Report.

<https://www.york.ca/environment/water-and-wastewater/drinking-water-quality-and-monitoring>



Notes:

- AWQI:** Adverse Water Quality Incident
- CFU:** Colony Forming Unit
- MAC:** Maximum Acceptable Concentration
- mg/L:** milligrams per litre
- ND:** Not detectable
- NTU:** Nephelometric Turbidity Unit
- P/A:** Presence / Absence
- µg/L:** micrograms per litre



Ministry of the Environment, Conservation & Parks
Inspection Report

APPENDIX B INSPECTION RATING RECORD (IRR)

Ministry of the Environment, Conservation and Parks - Inspection Summary Rating Record (Reporting Year - 2025-26)

DWS Name:	NEWMARKET DISTRIBUTION SYSTEM
DWS Number:	260003188
DWS Owner:	CORPORATION OF THE TOWN OF NEWMARKET
Municipal Location:	NEWMARKET
Regulation:	O.REG. 170/03
DWS Category:	DW Municipal Residential
Type of Inspection:	Detailed
Compliance Assessment Start Date:	Sep-24-2025
Ministry Office:	York Durham District Office

Maximum Risk Rating: 339

Inspection Module	Non Compliance Risk (X out of Y)
Certification and Training	0/49
Logbooks	0/30
Operations Manuals	0/42
Reporting & Corrective Actions	0/67
Treatment Processes	0/80
Water Quality Monitoring	0/71
Overall - Calculated	0/339

Inspection Risk Rating: 0.00%

Final Inspection Rating: 100.00%

Inspection Rating Record Generated On 2025-11-10 (Inspection ID: 1-1435058044)

Ministry of the Environment, Conservation and Parks - Detailed Inspection Rating Record (Reporting Year - 2025-26)

DWS Name:	NEWMARKET DISTRIBUTION SYSTEM
DWS Number:	260003188
DWS Owner Name:	CORPORATION OF THE TOWN OF NEWMARKET
Municipal Location:	NEWMARKET
Regulation:	O.REG. 170/03
DWS Category:	DW Municipal Residential
Type of Inspection:	Detailed
Compliance Assessment Start Date:	Sep-24-2025
Ministry Office:	York Durham District Office

All legislative requirements were met. No detailed rating scores.

Maximum Question Rating: 339

Inspection Risk Rating: 0.00%

FINAL INSPECTION RATING: 100.00%

Inspection Rating Record Generated On 2025-11-10 (Inspection ID: 1-1435058044)